

UNION BANK BUILDING

707 SW Washington, Portland, Oregon 97205

Collocation Facility Standards & Requirements

This document provides a list of services the Building will provide within the Collocation Facility.

- 1) The Building shall provide the tenant with the cabinet: Chatsworth M-Series Megaframe Cabinet, 84" H x 31.32" W x 39.62" D; Part Number M2053131, see CPI catalog pages 2-6 and 2-7.
- 2) One dedicated 20 Amp circuit with a four receptacle outlet per leased cabinet.
- 3) DC power may be purchased separately from the Building.
- 4) HVAC services are provided.
- 5) Fire suppression systems are provided.
- 6) Cable trays, cable ladder runways and wire management hardware will be provided.
- 7) Security protocols for access managed by 7 x 24 security guards; multiple security guards on-site at all times to provide managed access.
- 8) Access to riser shafts is provided.
- 9) Static tile floor covering is provided.